

TEST REPORT

DATE: 02-16-2023	Page 1 of 1	TEST NUMBER:	0293719
CLIENT	Egetaepper a/s		

TEST METHOD CONDUCTED	ASTM E662 Smoke Density (Non-Flaming) Standard Test Method for
TEST METHOD CONDUCTED	Specific Optical Density of Smoke Generated by Solid Materials



	DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Colortec 80/20 1800 LF	
CONSTRUCTION	Cut Pile	
BACKING	Attached Cushion	

GENERAL PRINCIPLE

This procedure is designed to measure the specific optical density of smoke generated by the test specimen within a closed chamber. Each specimen is exposed to an electrically heated radiant-energy source positioned to provide a constant irradiance level of 2.5 watts/square cm on the specimen surface. Measurements are recorded through a photometric system employing a vertical beam of light and a photo detector positioned to detect the attenuation of light transmittance caused by smoke accumulation within the chamber. The light transmittance measurements are used to calculate specific optical density, a quantitative value which can be factored to estimate the smoke potential of materials. Two burning conditions can be simulated by the test apparatus. The radiant heating in the absence of ignition is referred to as the Non-Flaming Mode. A flaming combustion in the presence of supporting radiation constitutes the Flaming Mode.

	CONDI	IIONS	
PREDRYING OF TEST SAMPLE	24 Hours at 140° F		
CONDITIONING OF TEST SAMPLE	24 Hours at 70° F an	d 50% Relative Humidity	
TESTING CONDITION	As Received		
FURNACE VOLTAGE	118 V	IRRADIANCE	2.5 watts/sq cm
CHAMBER TEMPERATURE	95° F	CHAMBER PRESSURE	3" H ₂ O
TEST MODE	Non-Flaming		

AVERAGE MAXIMUM DENSITY CORRECTS	D (Dmc)	NON-FLAMING	138
AVERAGE SPECIFIC OPTICAL DENSITY AT	4.0 MINUTES		54
	Specimen 1	Specimen 2	Specimen 3
Maximum Density (Dm)	147.0	156.0	128.0
Time to Dm (minutes)	20.0	20.0	20.0
Clear Beam (Dc)	5.0	6.0	5.0
Corr. Max Density (Dmc)	142.0	150.0	123.0
Density at 1.5 minutes	25.0	23.0	20.0
Density at 4.0 minutes	60.0	56.0	47.0
Time to 90% Dm (minutes)	14.0	14.0	15.5
Specimen Weight (grams)	15.5	15.4	14.9

APPROVED BY:

Hary Cusbury
This facility is accredited by the Na



This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, Inc. shall not be used under any circumstance in advertising to the general public.



283 Fax: 706-226-6787 protest@optilink.us



TEST REPORT

DATE: 02-16-2023	Page 1 of 1	TEST NUMBER: 0293719
CLIENT	Egetaepper a/s	

THE METHOD COMPUCTED	ASTM E662 Smoke Density (Flaming) Standard Test Method for Specific
TEST METHOD CONDUCTED	Optical Density of Smoke Generated by Solid Materials



	DESCRIPTION OF TEST SAMPLE
IDENTIFICATION	Colortec 80/20 1800 LF
CONSTRUCTION	Cut Pile
BACKING	Attached Cushion

GENERAL PRINCIPLE

This procedure is designed to measure the specific optical density of smoke generated by the test specimen within a closed chamber. Each specimen is exposed to an electrically heated radiant-energy source positioned to provide a constant irradiance level of 2.5 watts/square cm on the specimen surface. Measurements are recorded through a photometric system employing a vertical beam of light and a photo detector positioned to detect the attenuation of light transmittance caused by smoke accumulation within the chamber. The light transmittance measurements are used to calculate specific optical density, a quantitative value which can be factored to estimate the smoke potential of materials. Two burning conditions can be simulated by the test apparatus. The radiant heating in the absence of ignition is referred to as the Non-Flaming Mode. A flaming combustion in the presence of supporting radiation constitutes the Flaming Mode.

	CON	DITIONS	
PREDRYING OF TEST SAMPLE CONDITIONING OF TEST SAMPLE TESTING CONDITION 24 Hours at 140° F 24 Hours at 70° F and 50% Relative Humidity As Received			
FURNACE VOLTAGE CHAMBER TEMPERATURE TEST MODE	118 V 95° F Flaming	IRRADIANCE CHAMBER PRESSURE	2.5 watts/sq cm 3" H ₂ O

AVERAGE MAXIMUM DENSITY CORRECTE	D (Dmc)	FLAMING	190
AVERAGE SPECIFIC OPTICAL DENSITY AT 4.0 MINUTES			48
CONTRACTOR TO A PART AND THE COLD INCIDENCE OF THE COLD INCIDENCE	Specimen 1	Specimen 2	Specimen 3
Maximum Density (Dm)	201.0	247.0	165.0
Time to Dm (minutes)	10.5	10.5	10.5
Clear Beam (Dc)	11.0	16.0	15.0
Corr. Max Density (Dmc)	190.0	231.0	150.0
Density at 1.5 minutes	6.0	6.0	6.0
Density at 4.0 minutes	54.0	40.0	51.0
Time to 90% Dm (minutes)	9.0	8.5	7.5
Specimen Weight (grams)	15.0	15.1	15.0

APPROVED BY:

Day asbury



This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, Inc. shall not be used under any circumstance in advertising to the general public.



protest@optilink.us

Fax: 706-226-6787